



PICS EE600D & EE610D
BACnet Protocol
Implementation
Conformance Statement

YOUR PARTNER IN SENSOR TECHNOLOGY



ELEKTRONIK®
Ges.m.b.H.

Content

1.	GENERAL INFORMATION	3
2.	BACNET STANDARDIZED DEVICE PROFILE (ANNEX L).....	3
3.	LIST OF ALL SUPPORTED BACNET INTEROPERABILITY BUILDING BLOCKS (ANNEX K):	3
4.	SEGMENTATION CAPABILITY:.....	3
5.	BACNET STANDARD OBJECT TYPES SUPPORTED	3
6.	DATA LINK LAYER OPTIONS.....	4
7.	DEVICE ADDRESS BINDING.....	4
8.	NETWORKING OPTIONS	4
9.	NETWORK SECURITY OPTIONS	4
10.	CHARACTER SETS SUPPORTED	4
11.	TRANSMITTER DIFFERENCES	4
12.	BACNET OBJECTS.....	5
	12.1 Device Object	5
	12.2 Analog Input Objects	6
13.	MISCELLANEOUS INFORMATION	7

1. GENERAL INFORMATION

Date: 22.10.2019
Vendor Name: E+E Elektronik
Product Name: EE600D or EE610D
Product Model Number: EE600D or EE610D

These are the generic denominations for EE600 or EE610 devices with digital output (RS485) and BACnet MS/TP protocol. For type number of specific EE600D or EE610D devices see the respective data sheets at:
www.epluse.com/fileadmin/data/product/ee600/datasheet_EE600.pdf
www.epluse.com/fileadmin/data/product/ee610/datasheet_EE610.pdf

Application Software Version: 1.0
Firmware Revision: 1.0
BACnet Protocol Version: 1
BACnet Protocol Revision: 14

Product Description:

Differential pressure BACNet MS/TP Smart Sensor Master device.

- EE600D: pressure range 0 to 1000 Pa
- EE600D: pressure range 0 to 10000 Pa
- EE610D: pressure range +/- 100Pa

2. BACNET STANDARDIZED DEVICE PROFILE (ANNEX L)

- BACnet Operator Workstation (B-OWS)
- BACnet Advanced Operator Workstation (B-AWS)
- BACnet Operator Display (B-OD)
- BACnet Building Controller (B-BC)
- BACnet Advanced Application Controller (B-AAC)
- BACnet Application Specific Controller (B-ASC)
- BACnet Smart Sensor (B-SS)
- BACnet Smart Actuator (B-SA)

3. LIST OF ALL SUPPORTED BACNET INTEROPERABILITY BUILDING BLOCKS (ANNEX K):

DS-RP-B Data Sharing – Read Property – B
DS-RPM-B Data Sharing – Read Property Multiple – B
DS-WP-B Data Sharing – Write Property – B
DS-COVU-B Data Sharing – COV-Unsolicited – B
DM-DDB-B Data Management – Dynamic Device Binding – B
DM-DOB-B Data Management – Dynamic Object Binding – B
DM-DCC-B Data Management – Device Communication Control – B
DM-RD-B Data Management – Reinitialize Device – B

4. SEGMENTATION CAPABILITY:

- Able to transmit segmented messages
- Able to receive segmented messages

5. BACNET STANDARD OBJECT TYPES SUPPORTED

- | | | |
|--|--|---|
| <input type="checkbox"/> Accumulator | <input type="checkbox"/> Command | <input type="checkbox"/> Multistate Output |
| <input checked="" type="checkbox"/> Analog Input | <input checked="" type="checkbox"/> Device | <input type="checkbox"/> Multistate Value |
| <input type="checkbox"/> Analog Output | <input type="checkbox"/> Event Enrollment | <input type="checkbox"/> Notification Class |
| <input type="checkbox"/> Analog Value | <input type="checkbox"/> File | <input type="checkbox"/> Program |
| <input type="checkbox"/> Averaging | <input type="checkbox"/> Group | <input type="checkbox"/> Pulse Converter |
| <input type="checkbox"/> Binary Input | <input type="checkbox"/> Life Safety Point | <input type="checkbox"/> Schedule |
| <input type="checkbox"/> Binary Output | <input type="checkbox"/> Life Safety Zone | <input type="checkbox"/> Trend Log |
| <input type="checkbox"/> Binary Value | <input type="checkbox"/> Loop | |
| <input type="checkbox"/> Calendar | <input type="checkbox"/> Multistate Input | |

6. DATA LINK LAYER OPTIONS

- BACnet IP, (Annex J):
- BACnet IP, (Annex J), Foreign Device:
- ISO 8802-3, Ethernet (Clause 7):
- ATA 878.1, 2.5 Mb. ARCNET (Clause 8):
- ATA 878.1, EIA-485 ARCNET (Clause 8), baud rate(s):
- MS/TP master (Clause 9), baud rate(s): 9600, 19200, 38400, 57600, 76800, 115200
- MS/TP slave (Clause 9), baud rate(s):
- Point-To-Point, EIA 232 (Clause 10), baud rate(s):
- Point-To-Point, modem, (Clause 10), baud rate(s):
- LonTalk, (Clause 11), medium:
- BACnet/Zigbee (Annex O):
- Other:

7. DEVICE ADDRESS BINDING

Is static device binding supported? (This is currently necessary for two-way communication with MS/TP slaves and certain other devices.) Yes No

8. NETWORKING OPTIONS

- Router, Clause 6 - List all routing configurations, e.g., ARCNET-Ethernet, Ethernet-MS/TP, etc.
- Annex H, BACnet Tunneling Router over IP
- BACnet/IP Broadcast Management Device (BBMD)
 - Does the BBMD support registrations by Foreign Devices? Yes No
 - Does the BBMD support network address translation? Yes No

9. NETWORK SECURITY OPTIONS

- Non-secure Device - is capable of operating without BACnet Network Security
- Secure Device - is capable of using BACnet Network Security (NS-SD BIBB)
 - Multiple Application-Specific Keys
 - Supports encryption (NS-ED BIBB)
 - Key Server (NS-KS BIBB)

10. CHARACTER SETS SUPPORTED

Indicating support for multiple character sets does not imply that they can all be supported simultaneously.

- ISO 10646 (UTF-8) IBM™ /Microsoft™ DBCS ISO 8859-1
- ISO 10646 (UCS-2) SO 10646 (UCS-4) JIS X 0208

11. TRANSMITTER DIFFERENCES

BACnet Objects	EE600D	EE610D
Device Object	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>
Analog Input Object: Differential Pressure	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>
Analog Input Object: Air Velocity	<input checked="" type="checkbox"/>	
Analog Input Object: Volumetric Flow	<input checked="" type="checkbox"/>	
Analog Input Object: Filter Contamination	<input checked="" type="checkbox"/>	
Analog Input Object: Level Indicator	<input checked="" type="checkbox"/>	

12. BACNET OBJECTS

This part describes the various BACnet objects in detail. The main properties of the individual objects are explained in the following paragraphs.

12.1 Device Object

Property	Data Type	Initial Value	R/O/P	Persistence
Object Identifier	BACnetObjectIdentifier	Unique Object Instance (0 – 4194302)	R (W)	Non Volatile
Object Name	CharacterString[15]	“EE600D_XXXXXXXX” “EE610D_XXXXXXXX” (X ... Unique characters)	R (W)	Non Volatile
Object Type	BACnetObjectType (Enum.)	OBJECT_DEVICE	R (R)	Fixed
Description	CharacterString[15]	“EE600D” “EE610D”	O (W)	Non Volatile
System Status	BACnetDeviceStatus (Enum.)	STATUS_OPERATIONAL	R (R)	Volatile
Vendor Name	CharacterString	“E+E Elektronik”	R (R)	Fixed
Vendor Identifier	Unsigned16	623	R (R)	Fixed
Model Name	CharacterString	“EE600D” “EE610D”	R (R)	Fixed
Firmware Revision	CharacterString	“1.0”	R (R)	Fixed
Application Software Version	CharacterString	“1.0”	R (R)	Fixed
Location	CharacterString[15]	“AUT”	O (W)	Non Volatile
Protocol Version	Unsigned	1	R (R)	Fixed
Protocol Revision	Unsigned	14	R (R)	Fixed
Protocol Services Supported	BACnetProtocolServices Supported (Bit-String)	Read Property Read Property Multiple Write Property Device Comm. Control Reinitialize Device Who-Is Who-Has	R (R)	Fixed
Protocol Object Types Supported	BACnetObjectTypes Supported (Bit-String)	Device Analog Input	R (R)	Fixed
Object List	BACnetARRAY[N] of BACnetObjectIdentifier	EE600D: Device Object A10 (Differential pressure) A11 (Air velocity) A12 (Volumetric flow) A13 (Filter contamination) A14 (Level indicator) EE610D: Device Object A10 (Differential pressure)	R (R)	Fixed
Property List	BACnetARRAY[N] of BACnetPropertyIdentifier	System Status, Vendor Name, Vendor Identifier, Model Name, Firmware Revision, Application Software Version, Location, Description, Protocol Version, Protocol Revision, Protocol Services Supported, Protocol Object Types Supported, Object List, Max APDU Length Accepted, APDU Timeout, Segmentation Supported, Number of APDU Retries, Device Address Binding, Database Revision, Max Info Frames, Max Master, 512 (proprietary prop.: Comm. Settings)	R (R)	Fixed
Max APDU Length Accepted	Unsigned16	480	R (R)	Fixed
Segmentation Supported	BACnetSegmentation (Enum.)	NO_SEGMENTATION	R (R)	Fixed
APDU Timeout	Unsigned	3000	R (R)	Fixed
Number of APDU Retries	Unsigned	3	R (R)	Fixed
Device Address Binding	List of BACnetAddressBinding	NULL	R (R)	Fixed
Database Revision	Unsigned	0	R (W)	Non Volatile
Max Info Frames	Unsigned	1	O (R)	Fixed
Max Master	Unsigned	127	O (W)	Non Volatile
Communication Parameter	CharacterString	“38400-8n1”	P (W)	Non Volatile

- R (R) Required Property (Readable)
- R (W) Required Property (Read-/Writable)
- O (R) Optional Property (Readable)
- O (W) Optional Property (Read-/Writable)
- P (R) Proprietary Property (Readable)
- P (W) Proprietary Property (Read-/Writable)

Max Master Property:

The maximum “Max Master” value is 127. This value is writable via BACnet write property.

Communication Parameter Property:

For changing the RS485 communication parameters it is relevant to observe the character string format. The string consists of the following parts:

1. Baud rate (9600, 19200, 38400, 57600, 76800, 115200)
2. “-“
3. Number of data bits (8)
4. Parity (no)
5. Number of stop bits (1)

Example:

Change parameters to: Baud = 76800, 8 data bits, no parity, 1 stop bit:

String: “76800-8n1”

ATTENTION: The character string shall end with the terminating 0.

12.2 Analog Input Objects

Each analog input object has the same structure. It is the same for both, EE600D and EE610D.

Property	Data Type	Initial Value	R/O/P	Persistence
Object Identifier	BACnetObjectIdentifier	0 ... Differential pressure 1 ... Air velocity 2 ... Volumetric flow 3 ... Filter contamination 4 ... Level indicator	R	Fixed
Object Name	CharacterString	“p” ... Differential pressure “v” ... Air velocity “V” ... Volumetric flow “fc” ... Filter contamination “li” ... Level indicator	R	Fixed
Description	CharacterString	(see below)	O	Fixed
Object Type	BACnetObjectType (Enum.)	OBJECT_ANALOG_INPUT	R	Fixed
Present Value	Real	0.0	R (W) ^{a)}	Volatile
Status Flags	BACnetStatusFlags (Bit-String)	false, false, false, false	R	Volatile
Event State	BACnetEventState	NORMAL	R	Volatile
Out of Service	Boolean	false	R (W)	Volatile
Units	BACnetEngineeringUnits (Enum.)	(see below)	R (W)	Non Volatile
Reliability	BACnetReliability (Enum.)	NO_FAULT_DETECTED	R (W) ^{a)}	Volatile
COV Increment	Real	Not a Number (NaN)	O (W)	Non Volatile
Property List	BACnetARRAY[N] of BACnetPropertyIdentifier		R (R)	Fixed

a) When “Out of Service” flag is true, value is writable.

Description Property:

The following table lists the possible object descriptions depending on the selected measurement units:

Measurand	Initial Unit	Alternative 1	Alternative 2
p	“Differential pressure [Pa]”	“Differential pressure [kPa]”	“Differential pressure [mbar]”
	“Differential pressure [inch WC]”	“Differential pressure [mm WC]”	
v	“Air velocity [m/s]”	“Air velocity [ft/min]”	
V	“Volumetric flow [m³/h]”	“Volumetric flow [m³/s]”	“Volumetric flow [l/s]”
	“Volumetric flow [ft³/min]”		
fc	“Filter contamination [%]”		
li	“Level indicator [cm]”	“Level indicator [inch]”	“Temperature [deg. K]”

Present Value Property:

This property represents the actual sensor or actual calculated value. When the “Out of Service” flag is true, this value is writable. The default value is set to 50.0 in this case.

Status Flags Property:

The following table describes the possible states of the “Status Flags” property:

Flag	State	Reason
IN_ALARM	false	Value of “Event State” property is NORMAL (0)
	true	Value of “Event State” property is not NORMAL (0)
FAULT	false	Value of “Reliability” property is NO_FAULT_DETECTED
	true	Value of “Reliability” property is not NO_FAULT_DETECTED
OVERRIDDEN	false	Always false
OUT_OF_SERVICE	false	“Present Value” and “Reliability” properties are not writeable via BACnet
	true	“Present Value” and “Reliability” properties are writeable via BACnet

Event State Property:

The following table describes the possible states of the “Event State” property:

State	Reason
NORMAL (0)	Value of “Reliability” property is NO_FAULT_DETECTED
FAULT (1)	Value of “Reliability” property is not NO_FAULT_DETECTED

Units Property:

The following table lists the possible units for each analog input object:

Measurand	Units		
P	PASCALS (53)	KILOPASCALS (54)	MILLIBARS (134)
	INCHES_OF_WATER (58)	MILLIMETERS_OF_WATER (206)	-
v	METERS_PER_SECOND (74)	FEET_PER_MINUTE (77)	-
V'	CUBIC_METERS_PER_HOUR (135)	CUBIC_METERS_PER_SECOND (85)	LITERS_PER_SECOND (87)
	CUBIC_FEET_PER_MINUTE (84)	-	-
fc	PERCENT (98)	-	-
li	CENTIMETERS (118)	INCHES (32)	-

Reliability Property:

The following table describes the possible states of the “Reliability” property:

State	Reason
NO_FAULT_DETECTED (0)	No fault detected
NO_SENSOR (1)	Sensor is damaged or not connected

COV Increment Property:

Default value is NaN (not a number). When the “COV Increment Property” is NaN or greater than 1,000,000,000.0 then COV reporting is disabled.

13. MISCELLANEOUS INFORMATION

Reinitialize Device (RD):

The RD function is used to restart/ reboot the entire device via BACnet. To use the reinitialization functionality, a password is needed. The password is: “BACnet123”.

Device Communication Control (DCC):

The DCC functionality is used to stop initiating messages on the BACnet network. After receiving a DCC stop initiate message, the device does not respond to a request any more, except to RD or DCC requests. The use of the device communication control functionality is password protected. The password is: “BACnet123”.

Unsolicited COV Reporting:

When COV reporting is activated, a BACnet message is broadcasted every time when the difference between actual “Present Value” and the previous measured “Present Value” since last COV message exceeds the “COV Increment” value. Since no subscription list is supported, the COV message is always broadcasted. This function is useful for many BACnet clients which need the same information of one BACnet device (e.g. differential pressure).



HEADQUARTERS

E+E Elektronik Ges.m.b.H.

Langwiesen 7
A-4209 Engerwitzdorf
Austria
Tel: +43 7235 605 0
Fax: +43 7235 605 8
info@epluse.com
www.epluse.com

SUBSIDIARIES

E+E Elektronik Germany

info@epluse.de

Office Bad Homburg
Tel: +49 6172 13881-0

Office Hamburg
Tel: +49 160 9050 6460

Office Stuttgart
Tel: +49 151 538 37 500

E+E Elektronik Italy

info@epluse.it
Tel: +39 02 2707 86 36

E+E Elektronik France

info@epluse.fr
Tel: +33 4 74 72 35 82

E+E Elektronik USA

office@epluse.com
Office Boston
Tel: +1 847 490 0520

Office Chicago
Tel: +1 847 490 0520

E+E Elektronik Korea

Tel: +82 31 732 6050
info@epluse.co.kr

E+E Elektronik China

info@epluse.cn
Office Beijing
Tel: +86 10 8499 2361

Office Shanghai
Tel: +86 21 6117 6129

Office Guangzhou
Tel: +86 20 3898 7052

YOUR PARTNER IN SENSOR TECHNOLOGY



ELEKTRONIK®
Ges.m.b.H.